

Message

From: Bill Betters [bbetters@cdwconsultants.com]
Sent: 12/19/2016 8:24:52 PM
To: Kipka, Undine [kipka.undine@epa.gov]
CC: Houlihan, Damien [houlihan.damien@epa.gov]; Vakalopoulos, Catherine (DEP) [catherine.vakalopoulos@state.ma.us]; Nerden, Joseph (DEP) [joseph.nerden@state.ma.us]; COUTU Clary [clary.coutu@keoliscs.com]; Kearney, Janis [JKearney@MBTA.com]; Marian Rambelle [mrambelle@cdwconsultants.com]
Subject: RE: MBTA CRMF (MA0003590) - Response to request for monitoring changes
Attachments: Fig 1 - prop. metering locations DMH 13.4.pdf

Hello Undine,

Thank you for the December 16, 2016 approval letter for NPDES permit number MA0003590. I'd like to gain some clarification on the requirements for flow metering. The approval letter cites the permit requirements for metering prior to comingling. However, it appears that the recommendation is to meter the outfall pipes where they connect to Chamber 13.4, which will be after comingling. Are we to forgo the requirement of each co-permittee to meter flow and install the meters at the alternate location as indicated on the attached plan? Or should we install meters in upstream locations prior to comingling? Thank you in advance for your input.

Best,
Bill Betters

William J. Betters, P.G., L.S.P.
Director of Environmental Services

CDW CONSULTANTS, INC.
Civil and Environmental Engineers
40 Speen Street, Suite 301
Framingham, MA 01701
508-875-2657 x27

CDW is a SOMWBA-certified Minority/Woman-Owned Business and a DBE

The information contained in this transmission is privileged, confidential and intended only for the use of the individual or entity named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or the taking of any action in reliance on the contents of this e-mail transmission is strictly prohibited. If you received this communication in error, please notify CDW Consultants, Inc. immediately by e-mail. Thank you.

From: Kipka, Undine [mailto:kipka.undine@epa.gov]
Sent: Friday, December 16, 2016 4:17 PM
To: Bill Betters <bbetters@cdwconsultants.com>
Cc: Houlihan, Damien <houlihan.damien@epa.gov>; Vakalopoulos, Catherine (DEP) <catherine.vakalopoulos@state.ma.us>; Nerden, Joseph (DEP) <joseph.nerden@state.ma.us>; COUTU Clary <clary.coutu@keoliscs.com>; Kearney, Janis <JKearney@MBTA.com>; Marian Rambelle <mrambelle@cdwconsultants.com>
Subject: MBTA CRMF (MA0003590) - Response to request for monitoring changes

Mr. Betters,

The letter in response to your monitoring change request on behalf of MBTA and Keolis for the MBTA CRMF NPDES permit (MA0003590) is attached to this e-mail. A hard copy of the response will follow. Please let me know if you have any comments or questions in the meantime.

Kind regards,

Undine Kipka

Environmental Engineer

U.S. Environmental Protection Agency - Region 1

5 Post Office Square - OEP06-01

Boston, MA 02109-3912

(617) 918 1335



Please consider the environment before printing.